

**COLUMBUS CONSOLIDATED GOVERNMENT**  
*Georgia's First Consolidated Government*



FINANCE DEPARTMENT  
**PURCHASING DIVISION**

1111 First Avenue, P. O. Box 1340  
COLUMBUS, GEORGIA 31902-1340  
706-225-4087 | [www.columbusga.gov](http://www.columbusga.gov)

March 12, 2026

**ADDENDUM No. 6**  
**COMPREHENSIVE GENERATOR SERVICES**  
**(ANNUAL CONTRACT)**  
**RFB No. 26-0023**

**Use the form provided in the solicitation to acknowledge receipt of this addendum. Failure to do so may result in your submittal being deemed non-responsive and not receiving further consideration for award.**

Vendors are informed that the above subject solicitation is hereby modified, corrected, or supplemented as specified, described and set forth in this Addendum:

**I. DUE DATE EXTENSION**

**THE DUE DATE FOR THIS RFB HAS NOT CHANGED.**

**Bids are due on Wednesday, March 18, 2026, no later than 2:30 PM (Eastern).**

**II. QUESTION(S)/RESPONSE(S)**

Question 1: I am quoting the four-hour load bank test with the annual under annual inspection and maintenance. I am adding fuel analysis to this cost too. For the semi-annual, all I am quoting is an inspection for each generator. Is that correct?

**Response: That is correct**

**III. ACKNOWLEDGEMENT**

Indicate that your company has received this addendum on the appropriate Addenda Acknowledge form and include your form acknowledgment with your electronic bid response. **Failure to acknowledge receipt of this addendum may render your response "Incomplete"**.

**Andrea J. McCorvey**  
**Purchasing Manager**

